

## **Fire safety regulations baking/roasting, BBQ, food truck & stall.**

- Event request must be known to FSC-Security at least 4 weeks prior to commencement.
- No more butane/propane cylinders gel burners etc. shall be present in the stall, exclusively for this purpose, than is necessary for the proper functioning of the equipment.
- Cylinders should be kept at least two metres away from fire and protected from excessive heating by solar radiation or otherwise.
- The cylinders should be arranged and secured in such a way that they cannot fall over and are "safely" removed in case of fire.
- The high-pressure hoses specifically intended for butane/propane (not older than two years) must be attached to the regulator and burner with hose clamps.
- A ready-to-use and approved 6-litre foam extinguisher, a fire blanket, must be present with each fryer.
- Fire extinguishers should not be taken out of buildings; fire extinguishers can be borrowed through FSC-Security.
- There must be no highly flammable substances within a two-metre radius of the fryers.
- Each fryer must be fitted with a properly functioning thermostat or other safety device which, in the event of overheating of oil or fat, automatically switches the gas flame to the lowest setting or cuts off the gas supply.
- The supporting surface under the frying appliances must be non-combustible up to at least 10 centimetres outside the appliances, or covered with a non-combustible and poorly heat-conducting material.
- A well-fitting lid for immediate use should be provided with each baking or frying pan, which can be used to close the pan in case of fire.
- When using a BBQ, only charcoal and briquettes are allowed, for lighting, the use of flammable liquid is not allowed, use the special lighter cubes for this.
- Set-up locations for fryers of any kind will be determined by FSC-Security. This should definitely not be deviated from without permission.
- BBQ, foodtrucks and other roasting devices should be placed at least 10 metres outside the façade/building, also consider trees and low-hanging branches.
- Electric cooking-baking appliances must have approval according to NEN-3140 standard.
- When using LPG (food truck): You may use an LPG system to cook on, as long as this tank is not used to power the vehicle, i.e. a separate gas vapour tank to cook on cooking (and/or heating).
- FSC-Security can conduct and monitor compliance during the event. Instructions from FSC-Security shall be implemented without delay;
- If the event violates the (fire) safety requirements, the FSC-Security employee may immediately terminate the event;
- The Utrecht Fire Brigade may also carry out checks during events. Instructions from the Utrecht Fire Brigade take precedence over those of FSC-Security.
- For questions and or comments, please contact: FSC-Security  
Department of specialisations  
Leuvenplein 1  
3584CX Utrecht  
Security control room: 030.2531300/2100.

These guidelines were adopted on behalf of the BoG by the task force Safety and Environment Directorate of Property and Campus Development. Security carries out monitoring of compliance with the guidelines.